



Telephone:0484-2623576
email:-qcdlaluva@gmail.co

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB,ALUVA -683101
WATER ANALYSIS REPORT

Report No: KWA/QCDL-A /S/1394/2020-21

Date: 20.03.2021

Customer Name &Address Principal G.Krishnaveni, Kendriya VidyalayaNAD Aluva, HMT.Colony P.O, Kalamassery.	Date of Receipt	03.03.2021	
	Date of Sample received	05.03.2021	
	Sampling Done by	Customer	
	Sample Code	ALY/S/1394/3/21	
	Source of Sample	Well	
	Sample Quantity	125 ml	
Test performing dates : From: 05.03.2021 to 06.03.2021			
Sl. No.	Source	No of Coliforms per 100ml of sample	E.Coli in 100ml of sample
1	Water sample submitted by the customer	More than 100CFU/100ml	2CFU/100ml

Remarks:-

NB:-The result stated above related only to the sample(s) submitted for testing by the customer .The test certificate shall not be reproduced except in full without the written approval of the Laboratory

End of Report

Authorized By

KWA/QCDL/ALY/01-2020	Issue Date : 17.09.2020		
Ref No:Nil	Rev,Date :Nil	Page 1of 1	

Principle

ശ്രീ.കൃഷ്ണവേണി / S.KRISHNAVENI
പ്രധാന/Principal
കേന്ദ്രീയ വിദ്യാലയ/Kandriya Vidyalaya
എ.എ.ടി. കോളനി/NAD, Aluva
കോളനി പാസ്റ്റ്/H.M.T. Colony P.O.
കാലാശ്ശേരി-683103/Kalamassery-683103